LISTING SERVICE

LISTING No. 7300-1130:223

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: *Honeywell International Inc., 1500 W. Dundee Road, Arlington Heights, IL 60004-1472
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

DESIGN: Model XLS-SEC2 Security Loop Module, XLS-KPDISP Control and Display Module, 24DC12 Bell Interface, GFD Ground Fault Detector, XLS-CRC/XLS-CRCXM Card Reader Interface, CRCRL Relay Module, CRCSND Card Reader Sounder and CRCXF Transformer. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12-24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or authorized company identification, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed Models EST-3 fire alarm control units. (CSFM Listing No. 7165-1591:186 and 7170-1591:187)

NOTE:
1. Model CRCXF Transformers may not be used for Fire application, Grade A Local mercantile, Grade A, B, or C Central Station, Grade A Proprietary, or hold-up alarm applications.

2. Formerly 7300-1388:239

XLF: 7300-1591:209

*Re. 06-14-2003KK

Date Issued: **JUNE 22, 2004** *Listing Expires* **June 30, 2005**

Authorized By: **DIANE K. AREND**, *Senior Deputy Program Manager*